

Annual Drinking Water Quality Report
PAOLI WATER DEPARTMENT

IN 5259004

Annual Water Quality Report for the period of January 1 to December 31, 2019

For more information regarding this report contact:

This report is intended to provide you with important information about your Drinking water and the efforts made by the water system to provide safe drinking water

Josh Dixon, 812-723-2739

PAOLI WATER DEPARTMENT is a Purchase Surface Water Utility

WATER SOURCE:

In 2019, the sole source of the drinking water distributed throughout the Town of Paoli water system is surface water treated and supplied by the Patoka Lake Regional Water and Sewer District. As water travels over the surface of the land or through the ground it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity

Drinking water, including bottled water may reasonably expect to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the systems business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons, who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800)426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Source Water Information

SWA =Source Water Assessment

Source Water Name

Patoka Lake Regional Water IN-5219012

Type of Water
SW

Report Status
ACTIVE

Location
37 South, Sandyhook, and Unionville Road

2019 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG): The Level of a contaminant in drinking water below which there is no known or expected risk too health. ALGs allow for a margin of safety

Action Level: The concentration of a contaminant which, if exceeded, triggers, treatment or other requirements which a water system must follow

Lead and Copper	Date Sampled	MCLG	Action Level(AL)	90th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	9/12/2017	1.3	1.3	0.197	0	ppm	N	Erosion of natural deposits; leaching from wood preservatives; Corrosion of household plumbing systems
Lead	9/12/2017	0	15	2.6	0	ppb	N	Corrosion of household plumbing systems Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples

Maximum Contaminant Level or MCL:

The highest level of a contaminant the is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water, There is some convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Water Quality Test Results

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants

NA: Not Applicable

mrem: milligrams per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion-or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million-or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A Required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection by-products	Collection Date	Highest Level Detected	Range Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2019	2.2	.74-2.2	MRDLG=4	MRDL=4	ppm	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	2019	32.5	1.6-32.5	No Goal for the total	60	ppb	N	By-Product of drinking water disinfection
Total Trihalomethanes (TTHM)	2019	53	24-53	No Goal for the total	80	ppb	N	By-Product of drinking water disinfection

PATOKA LAKE REGIONAL WATER, IN-5219012

2019 Regulated Contaminants Detected

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites over AL	Units	Violation	Likely Source of Contamination
Copper	8/8/2017	1.3	1.3	0.24	0	ppm	N	Erosion of Natural deposits; leaching from wood preservatives; Corrosion of household plumbing systems
Lead	8/8/2017	0	15	5	2	ppb	N	Corrosion of household plumbing Systems; Erosion of natural deposits

Regulated Contaminants

Disinfection and Disinfection By-Products	Collection Date	Highest Level Detected	Range Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chloramines	Daily	4	2.1-4.0	MRDLG=4	MDRL=4	ppm	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	2019	45	25-45	No Goal for the total	60	ppb	N	By-Product of drinking water disinfection
Total Trihalomethanes (TTHM)	2019	69	22.3-69	No Goal for the total	80	ppb	N	By-Product of drinking water disinfection

Inorganic Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2019	0.027	N/A	2	2	ppm	N	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Fluoride	2019	0.9	N/A	2	1	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Radioactive Contaminants

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/Photon	6/7/2017	1.49	1.49-1.49	0	4	mrem/yr	N	Decay of natural and man-made deposits.

Synthetic organic contaminants including pesticides and herbicides

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2019	0.2	N/A	BDL	3	ppb	N	Runoff from herbicide used in row crops.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest Single Measurement	1 NTU	0.22	N	Soil Runoff

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration

95PT

Lowest monthly % meeting limit			N	Soil Runoff
--------------------------------	--	--	---	-------------

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violation section